

TS6-225 Overhead door closer

Standard fixing position

No cycles completed.

Specification	Requirement	Test result
Cycles completed	0	0 cycles
Ambient temp.	15 - 30° C	20°C
Closer temp	Within 2° of ambient	20°C
Opening moment. Closer size 3	Max opening torque 0 - 4°	23.7Nm
	Max opening torque 0 - 30°	23.7Nm
	Max opening torque 30 - 60°	15.8Nm
Closing moment. Closer size 3	Max closing moment 0 - 4°	19.5Nm
Efficiency	Size 3 closer	82.3%

